



Haryana Public Works (B&R) Department
Jagadhri Provincial Division, PWD B&R Br., Yamuna Nagar
Telephone No. 01732-237834
E-Mail pwd-eept-yamunanagar@hry.nic.in, exenyamunanagar@yahoo.com

To

The Principal
Govt. Model Senior Secondary School,
Jagadhri (Yamuna Nagar).

Memo No. 6395

Dated: 14-10-2020


Subject: Application for issuance of Certificate of Structure Safety of School Building.

Reference: Your office letter 149/20 dated 25.09.2020.

In this connection, it is intimated that the building of Govt. Model Senior Secondary School Jagadhri District Yamuna Nagar has been inspected by the SDE Provincial Sub division No.2 P.W.D B&R Branch Yamuna Nagar and has reported that there is no major damage visible in the building. However there is dampness cracks in plaster visible in some rooms. Apparently, building seems to be safe as on today, however as far seismic factor is concerned advice of structural consultant may be sought. Moreover, no structural design and drawing (duly proof checked from approved source/ reputed agency like Punjab Engineer college Chandigarh, NIT Kurukshetra and IIT Roorkee etc.) has been supplied along with application letter seeking structure safety certificate. The building Retail and IT Lab namely National Skill Qualification Framework(NSQF) has not been constructed with bricks or concrete. Hence this office can't issue structure safety certificate for this lab.

This is for your kind information and further necessary action please.

D. A. /Nil



Executive Engineer,
Jag. Provl Divn. PWD B&R Br.,
Yamuna Nagar

Endst No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provl. Sub Divn., No.2, PWD B&R Br Yamuna Nagar with reference to his office letter no 3981 dated 13.10.2020.

D. A. /Nil


Executive Engineer,
Jag. Provl Divn. PWD B&R Br.,
Yamuna Nagar

✓